



## Bid Notice Abstract

### Request for Quotation (RFQ)

**Reference Number** 5209859  
**Procuring Entity** CAUAYAN CITY WATER DISTRICT  
**Title** Dosing Pump  
**Area of Delivery** Isabela

<b>Solicitation Number:</b> 201803B	<b>Status</b>	<b>Closed</b>
<b>Trade Agreement:</b> Implementing Rules and Regulations	<b>Associated Components</b>	1
<b>Procurement Mode:</b> Shopping	<b>Bid Supplements</b>	0
<b>Classification:</b> Goods	<b>Document Request List</b>	3
<b>Category:</b> Water Service Connection Materials/Fittings	<b>Date Published</b>	08/03/2018
<b>Approved Budget for the Contract:</b> PHP 110,000.00	<b>Last Updated / Time</b>	08/03/2018 00:00 AM
<b>Delivery Period:</b> 7 Day/s	<b>Closing Date / Time</b>	14/03/2018 14:00 PM
<b>Client Agency:</b>		
<b>Contact Person:</b> JAYCIBETH TUNAC RAMIREZ SENIOR ENGINEER B 166 Africano cor. Burgos Sts., District 2 Cauayan City Isabela Philippines 3305 63-078-6521622  jaycibeth_1709@yahoo.com		

#### Description

1 unit Motor Driven Dosing Pump, Fitted with Single Phase, 230 Volts Variable Frequency Inverter, IP 55 Class F Protection rating with feed rate – 15.5 liters per hour and up to 15 bars design back pressure, control pump flow rate by Expandability for flow regulation thugh frequency inverter ( 10% - 20% of the flow ), Micrometric controller with safety locking, with PolyVinylidene DiFlouride – PVDF Pump end and its assembly is composed of Elastomer base reinforced with fibre and PTFE – Teflon clothing, removable and repairable suction and discharge valves sets in ceramic balls with FPM/EPDM o-ring seals fitted with air bleed valve for priming , Motor VFID is equipped with thermal sensor connected to PCB for high temperature protection and with 5 amperes fuse, Pow mA input, selectable through software

The unit comes with 2 meters PVC suction tubing, 7 meters discharge tubing, foot valve and injection valve.

Warranty: Eighteen (18) months from date of acceptance or from date of FOB delivery of supplies

Warranty conditions: Brand new unit replacement if unit becomes defective during period of operation covered by warranty.

#### Eligibility Documents Requirements:

1. Valid & current Mayor's Permit/Business Permit
2. Updated General Information Sheet (GIS)
3. Annual Income Tax Return/Business Tax Return, paid thru EFPS shall be accepted
4. Tax Clearance Certificate
5. Philgeps Certificate of Registration-Platinum Member
6. At least Twenty (20) years in trading business
7. LWUA Accredited

---

**Created by** JAYCIBETH TUNAC RAMIREZ

**Date Created** 07/03/2018

The PhilGEPS team is not responsible for any typographical errors or misinformation presented in the system. PhilGEPS only displays information provided for by its clients, and any queries regarding the postings should be directed to the contact person/s of the concerned party.